

## CHAPTER 82

### FIRE PREVENTION

**[HISTORY: Adopted 3-10-1992 Town Meeting Article No. I, 3-10-1992 as Article No. 6; Article. II, 3-10-1992 as Article No. 9. Amendments noted where applicable.]**

#### **GENERAL REFERENCES**

Building construction — See Ch. **58**.

Electrical standards — See Ch. **72**.

#### **ARTICLE I National Fire Prevention Code (§ 82-1 — § 82-2)**

**[Adopted 3-10-1992 Town Meeting Article No. 6; Amended August 1, 2016 Board of Selectmen]**

##### **§ 82-1 Adoption of standards.**

The town has chosen to adopt the National Fire Prevention Code, One [sic] 2009, as published by the NFPA, with amendments.

##### **§ 82-2 Residential Sprinklers.**

Any residential living unit that does not otherwise require a sprinkler system shall have a residential sprinkler system as provided for in NFPA 1, 2009 edition, NFPA 13D and NFPA 13R, Residential sprinkler systems, whenever any of the following conditions are present:

1. Whenever the living unit is located on an open Town road or Class V road that only has one means of ingress or egress (i.e. dead end street, or
2. Whenever any residence is located greater than 200' from any open Town road or Class V road, or
3. Whenever the residential building is situated such that, in the opinion of the Fire Chief, the Fire Department cannot access the building in a safe and normal manner.